

Koesterer, Elizabeth

From: Pierce, Anthony <Anthony.Pierce@dnr.mo.gov>
Sent: Friday, April 27, 2018 11:52 AM
To: Goetz, Mary; Matthews, Marc; Catlin, Kelley; Koesterer, Elizabeth
Cc: Jurgensmeyer, John; kathy.flippin@dnr.mo.gov; nicole.eby@dnr.mo.gov; Lyskowski, Danny
Subject: RE: Zero Rd Berger, Mo

Update

I followed-up with Three Rivers Electric and they did note the transformer had been drained and damaged. They removed the transformer, pad and surrounding soil, and backfilled with clean rock. They did preliminary PCB testing and that information will be included in their report. Primary contact is Bill Wibberg, bwibberg@threeriverselectric.com, 573-644-9000

Electricity will not be available onsite without significant rebuilding. Service was initially terminated 04/14/2017 due to failure to pay.

Thieves continue to enter and vandalize the property. The doors are being reclosed as best as possible. The previously impacted doors are being reused, further compromising their integrity.

From: Pierce, Anthony
Sent: Thursday, April 26, 2018 8:41 AM
To: 'Goetz, Mary (goetz.mary@epa.gov)'; 'Matthews, Marc (Matthews.Marc@epa.gov)'; 'Catlin, Kelley (Catlin.Kelley@epa.gov)'; 'Koesterer.Elizabeth@epa.gov'
Cc: Jurgensmeyer, John; Flippin, Kathy; Eby, Nicole; Lyskowski, Danny
Subject: Zero Rd Berger, Mo

Update—The utility company is onsite removing a transformer that apparently was live and probably contains PCBs. To my knowledge the vandals/thieves had not compromised the transformer, but had stripped parts attached to it.

Mr. Aichholz left a message stating the utility company had interest in the unit earlier this week and the neighbor just called to let me know there was activity onsite.

Tony Pierce
Environmental Specialist
Missouri Department of Natural Resources
Hazardous Waste Program, Compliance and Enforcement Section
P.O. Box 176
Jefferson City, MO 65102
(573) 751-3465
www.dnr.mo.gov/env/hwp
anthony.pierce@dnr.mo.gov

We'd like your feedback on the service you received from the Missouri Department of Natural Resources. Please consider taking a few minutes to complete the department's Customer Satisfaction Survey at surveymonkey.com/r/MoDNRsurvey. Thank you.

RCRA



573416